

OFFICE OF THE SUPERINTENDENT OF SCHOOLS
Ridgefield Park Public Schools
712 Lincoln Avenue
Ridgefield Park, New Jersey 07660

Eric W. Koenig
 Superintendent of Schools

Telephone: (201) 807-2638
 (201) 807-2640
 Fax: (201) 641-2203

August, 2016

Dear Parents/Guardians,

Due to the concerns raised about lead in drinking water that was found in several school districts around the State, the Ridgefield Park School District made a decision to test the lead levels in the drinking fountains and other water sources in all of the district school buildings this past Spring.

The district contracted with ALS Environmental to conduct the tests. Samples were collected on May 24th and 25th according to specific sampling guidelines. Below is a summary of the results recorded in analytic reports received in June. According to federal regulations, an acceptable lead level for potable water sources is **.015 PPM**.

Lead Testing Summary

School	Total Sites Tested	# Sites No Lead Detected	# Sites with levels less than .015	# Sites Exceeding .015	Potable Sites Exceeding .015 (water fountains or food prep stations)
Grant	16	3	10	3	0
Lincoln	29	18	9	2	0
RPJSHS	39	4	16	19	3
Roosevelt	13	6	3	4	0
TJELC	14	8	6	0	0

While I am happy to report that very few potable sites tested above allowable levels, it is imperative that every precaution is taken to ensure the safety of everyone in our school community. As such, the potable sites exceeding the lowest allowable limit (listed below) were all shut down pending further action by the district.

JSHS Water Fountain by elevator (1st Floor)
 JSHS Water Fountain by AV Office
 JSHS Water Fountain by Rm 117

The full environmental reports can be found on the district website, in the Business Office or in the Main Office of each respective school.

Should you have any questions or concerns, feel free to contact your building principal.

Best regards,

Eric W. Koenig
 Superintendent of Schools

June 8, 2016

Mr. Mike Alberque
Ridgefield Park School District
712 Lincoln Ave.
Ridgefield Park, NJ 07660

Certificate of Analysis

Project Name: 2016PC- Lead Testing in Drinking	Workorder: 2147251
Purchase Order:	Workorder ID: Roosevelt School-Lead in DW

Dear Mr. Alberque:

Enclosed are the analytical results for samples received by the laboratory on Friday, May 27, 2016.

The ALS Environmental laboratory in Middletown, Pennsylvania is a National Environmental Laboratory Accreditation Program (NELAP) accredited laboratory and as such, certifies that all applicable test results meet the requirements of NELAP.

If you have any questions regarding this certificate of analysis, please contact Mrs. Kelli L Wolfgang (Project Coordinator) at (717) 944-5541.

Analyses were performed according to our laboratory's NELAP-approved quality assurance program and any applicable state requirements. The test results meet requirements of the current NELAP standards or state requirements, where applicable. For a specific list of accredited analytes, refer to the certifications section of the ALS website at www.alsglobal.com/en/Our-Services/Life-Sciences/Environmental/Downloads.

This laboratory report may not be reproduced, except in full, without the written approval of ALS Environmental.

ALS Spring City: 10 Riverside Drive, Spring City, PA 19475 610-948-4903

Mrs. Kelli L Wolfgang
Project Coordinator

This page is included as part of the Analytical Report and must be retained as a permanent record thereof.

ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

SAMPLE SUMMARY

Workorder: 2147251 Roosevelt School-Lead in DW

Lab ID	Sample ID	Matrix	Date Collected	Date Received	Collected By
2147251001	RS-BM-KTN	Drinking Water	5/24/2016 06:15	5/27/2016 19:00	Collected by Client
2147251002	RS-1F-FBR	Drinking Water	5/24/2016 06:45	5/27/2016 19:00	Collected by Client
2147251003	RS-1F-HWF	Drinking Water	5/24/2016 06:45	5/27/2016 19:00	Collected by Client
2147251004	RS-1F-104	Drinking Water	5/24/2016 06:45	5/27/2016 19:00	Collected by Client
2147251005	RS-1F-GBR	Drinking Water	5/24/2016 06:45	5/27/2016 19:00	Collected by Client
2147251006	RS-1F-BBR	Drinking Water	5/24/2016 06:45	5/27/2016 19:00	Collected by Client
2147251007	RS-1F-NO	Drinking Water	5/24/2016 06:45	5/27/2016 19:00	Collected by Client
2147251008	RS-2F-208	Drinking Water	5/24/2016 06:45	5/27/2016 19:00	Collected by Client
2147251009	RS-2F-N206	Drinking Water	5/24/2016 06:45	5/27/2016 19:00	Collected by Client
2147251010	RS-2F-FR	Drinking Water	5/24/2016 06:45	5/27/2016 19:00	Collected by Client
2147251011	RS-2F-GBR	Drinking Water	5/24/2016 06:45	5/27/2016 19:00	Collected by Client
2147251012	RS-2F-HWF	Drinking Water	5/24/2016 06:45	5/27/2016 19:00	Collected by Client
2147251013	RS-3F-BBR	Drinking Water	5/24/2016 06:45	5/27/2016 19:00	Collected by Client

ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
Vancouver Waterloo · Winnipeg · Yellowknife **United States:** Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York **Mexico:** Monterrey

SAMPLE SUMMARY

Workorder: 2147251 Roosevelt School-Lead in DW

Notes

- Samples collected by ALS personnel are done so in accordance with the procedures set forth in the ALS Field Sampling Plan (20 - Field Services Sampling Plan).
- All Waste Water analyses comply with methodology requirements of 40 CFR Part 136.
- All Drinking Water analyses comply with methodology requirements of 40 CFR Part 141.
- Unless otherwise noted, all quantitative results for soils are reported on a dry weight basis.
- The Chain of Custody document is included as part of this report.
- All Library Search analytes should be regarded as tentative identifications based on the presumptive evidence of the mass spectra. Concentrations reported are estimated values.
- Parameters identified as "analyze immediately" require analysis within 15 minutes of collection. Any "analyze immediately" parameters not listed under the header "Field Parameters" are performed in the laboratory and are therefore analyzed out of hold time.
- Method references listed on this report beginning with the prefix "S" followed by a method number (such as S2310B-97) refer to methods from "Standard Methods for the Examination of Water and Wastewater".
- For microbiological analyses, the "Prepared" value is the date/time into the incubator and the "Analyzed" value is the date/time out the incubator.

Standard Acronyms/Flags

J	Indicates an estimated value between the Method Detection Limit (MDL) and the Practical Quantitation Limit (PQL) for the analyte
U	Indicates that the analyte was Not Detected (ND)
N	Indicates presumptive evidence of the presence of a compound
MDL	Method Detection Limit
PQL	Practical Quantitation Limit
RDL	Reporting Detection Limit
ND	Not Detected - indicates that the analyte was Not Detected at the RDL
Cntr	Analysis was performed using this container
RegLmt	Regulatory Limit
LCS	Laboratory Control Sample
MS	Matrix Spike
MSD	Matrix Spike Duplicate
DUP	Sample Duplicate
%Rec	Percent Recovery
RPD	Relative Percent Difference
LOD	DoD Limit of Detection
LOQ	DoD Limit of Quantitation
DL	DoD Detection Limit
I	Indicates reported value is greater than or equal to the Method Detection Limit (MDL) but less than the Report Detection Limit (RDL)
(S)	Surrogate Compound
NC	Not Calculated
*	Result outside of QC limits

ALS Environmental Laboratory Locations Across North America


Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

ANALYTICAL RESULTS

Workorder: 2147251 Roosevelt School-Lead in DW

Lab ID: **2147251001** Date Collected: 5/24/2016 06:15 Matrix: Drinking Water
 Sample ID: **RS-BM-KTN** Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
METALS										
Lead, Total	ND		mg/L	0.0020	EPA 200.8	6/7/16 16:27	MO	6/7/16 19:15	MO	A1



Mrs. Kelli L Wolfgang
 Project Coordinator

ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

ANALYTICAL RESULTS

Workorder: 2147251 Roosevelt School-Lead in DW

Lab ID: **2147251002** Date Collected: 5/24/2016 06:45 Matrix: Drinking Water
 Sample ID: **RS-1F-FBR** Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
METALS										
Lead, Total	ND		mg/L	0.0020	EPA 200.8	6/7/16 16:27	MO	6/7/16 19:17	MO	A1



Mrs. Kelli L Wolfgang
 Project Coordinator

ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

ANALYTICAL RESULTS

Workorder: 2147251 Roosevelt School-Lead in DW

Lab ID: **2147251003** Date Collected: 5/24/2016 06:45 Matrix: Drinking Water
 Sample ID: **RS-1F-HWF** Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
METALS										
Lead, Total	0.0078		mg/L	0.0020	EPA 200.8	6/7/16 16:27	MO	6/7/16 19:20	MO	A1



Mrs. Kelli L Wolfgang
 Project Coordinator

ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

ANALYTICAL RESULTS

Workorder: 2147251 Roosevelt School-Lead in DW

Lab ID: **2147251004** Date Collected: 5/24/2016 06:45 Matrix: Drinking Water
 Sample ID: **RS-1F-104** Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
METALS										
Lead, Total	0.021		mg/L	0.0020	EPA 200.8	6/7/16 16:27	MO	6/7/16 19:23	MO	A1



Mrs. Kelli L Wolfgang
 Project Coordinator

ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

ANALYTICAL RESULTS

Workorder: 2147251 Roosevelt School-Lead in DW

Lab ID: **2147251005** Date Collected: 5/24/2016 06:45 Matrix: Drinking Water
 Sample ID: **RS-1F-GBR** Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
METALS										
Lead, Total	0.015		mg/L	0.0020	EPA 200.8	6/7/16 16:27	MO	6/7/16 19:31	MO	A1



Mrs. Kelli L Wolfgang
 Project Coordinator

ALS Environmental Laboratory Locations Across North America


Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

ANALYTICAL RESULTS

Workorder: 2147251 Roosevelt School-Lead in DW

Lab ID: **2147251006** Date Collected: 5/24/2016 06:45 Matrix: Drinking Water
 Sample ID: **RS-1F-BBR** Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
METALS										
Lead, Total	ND		mg/L	0.0020	EPA 200.8	6/7/16 16:27	MO	6/7/16 19:34	MO	A1



Mrs. Kelli L Wolfgang
 Project Coordinator

ALS Environmental Laboratory Locations Across North America


Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

ANALYTICAL RESULTS

Workorder: 2147251 Roosevelt School-Lead in DW

Lab ID: **2147251007** Date Collected: 5/24/2016 06:45 Matrix: Drinking Water
 Sample ID: **RS-1F-NO** Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
METALS										
Lead, Total	ND		mg/L	0.0020	EPA 200.8	6/8/16 00:51	ZMC	6/8/16 06:31	ZMC	A1



Mrs. Kelli L Wolfgang
 Project Coordinator

ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

ANALYTICAL RESULTS

Workorder: 2147251 Roosevelt School-Lead in DW

Lab ID: **2147251008** Date Collected: 5/24/2016 06:45 Matrix: Drinking Water
 Sample ID: **RS-2F-208** Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
METALS										
Lead, Total	0.027		mg/L	0.0020	EPA 200.8	6/8/16 00:51	ZMC	6/8/16 06:44	ZMC	A1



Mrs. Kelli L Wolfgang
 Project Coordinator

ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

ANALYTICAL RESULTS

Workorder: 2147251 Roosevelt School-Lead in DW

Lab ID: **2147251009** Date Collected: 5/24/2016 06:45 Matrix: Drinking Water
 Sample ID: **RS-2F-N206** Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
METALS										
Lead, Total	0.0035		mg/L	0.0020	EPA 200.8	6/8/16 00:51	ZMC	6/8/16 06:47	ZMC	A1



Mrs. Kelli L Wolfgang
 Project Coordinator

ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

ANALYTICAL RESULTS

Workorder: 2147251 Roosevelt School-Lead in DW

Lab ID: **2147251010** Date Collected: 5/24/2016 06:45 Matrix: Drinking Water
 Sample ID: **RS-2F-FR** Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
METALS										
Lead, Total	0.0046		mg/L	0.0020	EPA 200.8	6/8/16 00:51	ZMC	6/8/16 06:49	ZMC	A1



Mrs. Kelli L Wolfgang
 Project Coordinator

ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

ANALYTICAL RESULTS

Workorder: 2147251 Roosevelt School-Lead in DW

Lab ID: **2147251011** Date Collected: 5/24/2016 06:45 Matrix: Drinking Water
 Sample ID: **RS-2F-GBR** Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
METALS										
Lead, Total	0.022		mg/L	0.0020	EPA 200.8	6/8/16 00:51	ZMC	6/8/16 06:52	ZMC	A1



Mrs. Kelli L Wolfgang
 Project Coordinator

ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

ANALYTICAL RESULTS

Workorder: 2147251 Roosevelt School-Lead in DW

Lab ID: **2147251012** Date Collected: 5/24/2016 06:45 Matrix: Drinking Water
 Sample ID: **RS-2F-HWF** Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
METALS										
Lead, Total	ND		mg/L	0.0020	EPA 200.8	6/8/16 00:51	ZMC	6/8/16 06:55	ZMC	A1



Mrs. Kelli L Wolfgang
 Project Coordinator

ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey

ANALYTICAL RESULTS

Workorder: 2147251 Roosevelt School-Lead in DW

Lab ID: **2147251013** Date Collected: 5/24/2016 06:45 Matrix: Drinking Water
 Sample ID: **RS-3F-BBR** Date Received: 5/27/2016 19:00

Parameters	Results	Flag	Units	RDL	Method	Prepared	By	Analyzed	By	Cntr
METALS										
Lead, Total	ND		mg/L	0.0020	EPA 200.8	6/8/16 00:51	ZMC	6/8/16 06:57	ZMC	A1



Mrs. Kelli L Wolfgang
 Project Coordinator

ALS Environmental Laboratory Locations Across North America

Canada: Burlington · Calgary · Centre of Excellence · Edmonton · Fort McMurray · Fort St. John · Grande Prairie · London · Mississauga · Richmond Hill · Saskatoon · Thunder Bay
 Vancouver Waterloo · Winnipeg · Yellowknife United States: Cincinnati · Everett · Fort Collins · Holland · Houston · Middletown · Salt Lake City · Spring City · York Mexico: Monterrey



34 Dogwood Lane
Middletown, PA 17057
P. 717-944-5541
F. 717-944-1430

Environmental

**CHAIN OF CUSTODY/
REQUEST FOR ANALYSIS**
ALL SHADED AREAS MUST BE COMPLETED BY THE CLIENT/
SAMPLER. INSTRUCTIONS ON THE BACK.

COC #:
ALS QUO:



Client Name: <u>Ridgefield Park School District</u>		Container Type: <u>P</u>	Receiving Laboratory (Completed by Receiving Lab)
Address: <u>712 Lincoln Avenue</u>		Container Size: <u>250 mL</u>	Cooler Temp: <u>36.0</u> Therm ID: <u>360</u>
Contact: <u>Mike Alberque</u>		Preservative: <u>HNO3</u>	No. of Coolers: <u> </u> Y <u> </u> N <u> </u> Initial: <u> </u>
Phone#: <u>201-440-0808</u>		Custody Seals Present? <u> </u> (if present) Seals Intact? <u> </u> Received on Ice? <u> </u> COC Labels Complete/Accurate? <u> </u> Cont. in Good Cond.? <u> </u> Correct Containers? <u> </u> Correct Sample Volumes? <u> </u> Correct Preservation? <u> </u> HeadSpace/Volatiles? <u> </u>	
Project Name#: <u>Roosevelt School - Lead in DW</u>		COURTESY TRACKING #:	
Bill To:		Sample/COC Comments	
TAT <input checked="" type="checkbox"/> Normal-Standard TAT is 10-12 business days. <input type="checkbox"/> Rush-Subject to ALS approval and surcharges.		Enter Number of Containers Per Sample or Field Results Below.	
Date Required: <u> </u> Approved By: <u> </u>		Total Lead by EPA 200.8 <u> </u>	
Email? <input checked="" type="checkbox"/> -Y <u>malberque@rpps.net</u>		ANALYSES/METHOD REQUESTED	
Fax? <input type="checkbox"/> -Y No: <u> </u>		Matrix	
Sample Description/Location (as it will appear on the lab report)		Sample Date	Time
1 RS-BM-KTN		5/24	6:15
2 RS-1F-FBR			6:45
3 RS-1F-HWF			6:45
4 RS-1F-104			6:45
5 RS-1F-GBR			6:45
6 RS-1F-BBR			6:45
7 RS-1F-NO			6:45
8 RS-2F-208			6:45
9 RS-2F-N206			6:45
10 RS-2F-FR			6:45
Project Comments:		LOGGED BY (signature): <u> </u>	Date: <u>5/24/16</u> # <u>7 PA</u>
		REVIEWED BY (signature): <u> </u>	Date: <u>5/24/16</u> # <u>9 PA</u>
Relinquished By / Company Name	Date	Time	Received By / Company Name
1 <u> </u>			<u> </u>
3 <u> </u>			<u> </u>
5 <u> </u>			<u> </u>
7 <u> </u>			<u> </u>
9 <u> </u>			<u> </u>
Special Processing		State Samples Collected In	
USACE <input type="checkbox"/> Navy <input type="checkbox"/>		NY <input type="checkbox"/> NJ <input type="checkbox"/> PA <input type="checkbox"/> NC <input type="checkbox"/>	
Reportable to PADEP? Yes <input type="checkbox"/>		Sample Disposal Lab <input type="checkbox"/> Special <input type="checkbox"/>	
PWSID # <u> </u>		EDDS: Format Type <u> </u>	

* G=Grab, C=Composite **Matrix - AI=Air, DW=Drinking Water, GW=Groundwater, OB=Oil, OL=Other Liquid, SL=Sludge, SO=Soil, WP=Wipe, WW=Wastewater
ALS ENVIRONMENTAL SHIPPING ADDRESS: 34 DOGWOOD LANE, MIDDLETOWN, PA 17057 Rev 10/11





34 Dogwood Lane
Middletown, PA 17057
P. 717-944-5541
F. 717-944-1430

Environmental

Client Name: Ridgefield Park School District

Address: 712 Lincoln Avenue

Ridgefield Park, NJ 07660

Contact: Mike Alberque

Phone#: 201-440-0808

Project Name#: Roosevelt School - Lead in DW

Bill To:

TAT Normal-Standard TAT is 10-12 business days.
 Rush-Subject to ALS approval and surcharges.

Date Required: _____ Approved By: _____

Email? -Y malberque@rpps.net

Fax? -Y No: _____

Sample Description/Location
(as it will appear on the lab report)

Sample Date Time

1 RS-2F-GBR 5/24 6:45 G DW 1
2 RS-2F-HWF 6:45 G DW 1
3 RS-2F-8BR 6:45 G DW 1

Enter Number of Containers Per Sample or Field Results Below.

Total Lead by EPA 200.8

**CHAIN OF CUSTODY/
REQUEST FOR ANALYSIS**
ALL SHADED AREAS MUST BE COMPLETED BY THE CLIENT/
SAMPLER. INSTRUCTIONS ON THE BACK.

COC #: 251
ALS Quote #:

Receipt Information (Completed by Receiving Lab)

Cooler Temp: 300 Therm ID: 300

No. of Coolers: Y N Initial: *efu*

Custody Seals Present? Y N

(If present) Seals Intact? Y N

Received on Ice? Y N

COC/Labels Complete/Accurate? Y N

Cont. in Good Cond.? Y N

Correct Containers? Y N

Correct Sample Volumes? Y N

Correct Preservation? Y N

Headspace/Volatiles? Y N

Courier/Tracking #: _____

Sampler/COC Comments

Special Processing

Standard CLP-like USACE

Deliverables

Reportable to PADEP? Yes No

PWSID # _____

EDDS: Format Type _____

ALS Field Services: Pickup Labor Rental Equipment Other: _____

State Samples Collected In

USACE Navy NY NJ PA NC

Sample Disposal Lab Special

LOGGED BY (signature): *Mike Alberque* 5/24 7:00 AM

REVIEWED BY (signature): *M. Malberque* 5/25 9:00 AM

Relinquished By / Company Name

Date Time

1 *Malberque* 5/22 13:45

3 *Malberque* 5/22 16:00

5 *Malberque* 5/27/16 19:00

7 _____

9 _____

Project Comments:

10

ALS Environmental

34 Dogwood Lane
Middletown, PA 17057
P. 717-944-5541
F. 717-944-1430

Client Name: Ridgefield Park School District

Address: 712 Lincoln Avenue

Ridgefield Park, NJ 07660

Contact: Mike Alberque

Phone#: 201-440-0808

Project Name#: Roosevelt School - Lead in DW

Bill To:

TAT Normal-Standard TAT is 10-12 business days.
 Rush-Subject to ALS approval and surcharges.

Date Required: _____ Approved By: _____

Email? -Y malberque@rpps.net

Fax? -Y No: _____

Sample Description/Location
(as it will appear on the lab report)

Sample Date Time

1 RS-2F-GBR 5/24 6:45 G DW 1
2 RS-2F-HWF 6:45 G DW 1
3 RS-2F-8BR 6:45 G DW 1

Enter Number of Containers Per Sample or Field Results Below.

Total Lead by EPA 200.8

Special Processing

Standard CLP-like USACE

Deliverables

Reportable to PADEP? Yes No

PWSID # _____

EDDS: Format Type _____

ALS Field Services: Pickup Labor Rental Equipment Other: _____

State Samples Collected In

USACE Navy NY NJ PA NC

Sample Disposal Lab Special

LOGGED BY (signature): *Mike Alberque* 5/24 7:00 AM

REVIEWED BY (signature): *M. Malberque* 5/25 9:00 AM

Relinquished By / Company Name

Date Time

1 *Malberque* 5/22 13:45

3 *Malberque* 5/22 16:00

5 *Malberque* 5/27/16 19:00

7 _____

9 _____

Project Comments:

10

ALS Environmental

34 Dogwood Lane
Middletown, PA 17057
P. 717-944-5541
F. 717-944-1430

Client Name: Ridgefield Park School District

Address: 712 Lincoln Avenue

Ridgefield Park, NJ 07660

Contact: Mike Alberque

Phone#: 201-440-0808

Project Name#: Roosevelt School - Lead in DW

Bill To:

TAT Normal-Standard TAT is 10-12 business days.
 Rush-Subject to ALS approval and surcharges.

Date Required: _____ Approved By: _____

Email? -Y malberque@rpps.net

Fax? -Y No: _____

Sample Description/Location
(as it will appear on the lab report)

Sample Date Time

1 RS-2F-GBR 5/24 6:45 G DW 1
2 RS-2F-HWF 6:45 G DW 1
3 RS-2F-8BR 6:45 G DW 1

Enter Number of Containers Per Sample or Field Results Below.

Total Lead by EPA 200.8

Special Processing

Standard CLP-like USACE

Deliverables

Reportable to PADEP? Yes No

PWSID # _____

EDDS: Format Type _____

ALS Field Services: Pickup Labor Rental Equipment Other: _____

State Samples Collected In

USACE Navy NY NJ PA NC

Sample Disposal Lab Special

LOGGED BY (signature): *Mike Alberque* 5/24 7:00 AM

REVIEWED BY (signature): *M. Malberque* 5/25 9:00 AM

Relinquished By / Company Name

Date Time

1 *Malberque* 5/22 13:45

3 *Malberque* 5/22 16:00

5 *Malberque* 5/27/16 19:00

7 _____

9 _____

Project Comments:

10

ALS Environmental

34 Dogwood Lane
Middletown, PA 17057
P. 717-944-5541
F. 717-944-1430

Client Name: Ridgefield Park School District

Address: 712 Lincoln Avenue

Ridgefield Park, NJ 07660

Contact: Mike Alberque

Phone#: 201-440-0808

Project Name#: Roosevelt School - Lead in DW

Bill To:

TAT Normal-Standard TAT is 10-12 business days.
 Rush-Subject to ALS approval and surcharges.

Date Required: _____ Approved By: _____

Email? -Y malberque@rpps.net

Fax? -Y No: _____

Sample Description/Location
(as it will appear on the lab report)

Sample Date Time

1 RS-2F-GBR 5/24 6:45 G DW 1
2 RS-2F-HWF 6:45 G DW 1
3 RS-2F-8BR 6:45 G DW 1

Enter Number of Containers Per Sample or Field Results Below.

Total Lead by EPA 200.8

Special Processing

Standard CLP-like USACE

Deliverables

Reportable to PADEP? Yes No

PWSID # _____

EDDS: Format Type _____

ALS Field Services: Pickup Labor Rental Equipment Other: _____

State Samples Collected In

USACE Navy NY NJ PA NC

Sample Disposal Lab Special

LOGGED BY (signature): *Mike Alberque* 5/24 7:00 AM

REVIEWED BY (signature): *M. Malberque* 5/25 9:00 AM

Relinquished By / Company Name

Date Time

1 *Malberque* 5/22 13:45

3 *Malberque* 5/22 16:00

5 *Malberque* 5/27/16 19:00

7 _____

9 _____

Project Comments:

10

ALS Environmental

34 Dogwood Lane
Middletown, PA 17057
P. 717-944-5541
F. 717-944-1430

Client Name: Ridgefield Park School District

Address: 712 Lincoln Avenue

Ridgefield Park, NJ 07660

Contact: Mike Alberque

Phone#: 201-440-0808

Project Name#: Roosevelt School - Lead in DW

Bill To:

TAT Normal-Standard TAT is 10-12 business days.
 Rush-Subject to ALS approval and surcharges.

Date Required: _____ Approved By: _____

Email? -Y malberque@rpps.net

Fax? -Y No: _____

Sample Description/Location
(as it will appear on the lab report)

Sample Date Time

1 RS-2F-GBR 5/24 6:45 G DW 1
2 RS-2F-HWF 6:45 G DW 1
3 RS-2F-8BR 6:45 G DW 1

Enter Number of Containers Per Sample or Field Results Below.

Total Lead by EPA 200.8

Special Processing

Standard CLP-like USACE

Deliverables

Reportable to PADEP? Yes No

PWSID # _____

EDDS: Format Type _____

ALS Field Services: Pickup Labor Rental Equipment Other: _____

State Samples Collected In

USACE Navy NY NJ PA NC

Sample Disposal Lab Special

LOGGED BY (signature): *Mike Alberque* 5/24 7:00 AM

REVIEWED BY (signature): *M. Malberque* 5/25 9:00 AM

Relinquished By / Company Name

Date Time

1 *Malberque* 5/22 13:45

3 *Malberque* 5/22 16:00

5 *Malberque* 5/27/16 19:00

7 _____

9 _____

Project Comments:

10

ALS Environmental

34 Dogwood Lane
Middletown, PA 17057
P. 717-944-5541
F. 717-944-1430

Client Name: Ridgefield Park School District

Address: 712 Lincoln Avenue

Ridgefield Park, NJ 07660

Contact: Mike Alberque

Phone#: 201-440-0808

Project Name#: Roosevelt School - Lead in DW

Bill To:

TAT Normal-Standard TAT is 10-12 business days.
 Rush-Subject to ALS approval and surcharges.

Date Required: _____ Approved By: _____

Email? -Y malberque@rpps.net

Fax? -Y No: _____

Sample Description/Location
(as it will appear on the lab report)

Sample Date Time

1 RS-2F-GBR 5/24 6:45 G DW 1
2 RS-2F-HWF 6:45 G DW 1
3 RS-2F-8BR 6:45 G DW 1

Enter Number of Containers Per Sample or Field Results Below.

Total Lead by EPA 200.8

Special Processing

Standard CLP-like USACE

Deliverables

Reportable to PADEP? Yes No

PWSID # _____

EDDS: Format Type _____

ALS Field Services: Pickup Labor Rental Equipment Other: _____

State Samples Collected In

USACE Navy NY NJ PA NC

Sample Disposal Lab Special

LOGGED BY (signature): *Mike Alberque* 5/24 7:00 AM

REVIEWED BY (signature): *M. Malberque* 5/25 9:00 AM

Relinquished By / Company Name

Date Time

1 *Malberque* 5/22 13:45

3 *Malberque* 5/22 16:00

5 *Malberque* 5/27/16 19:00

7 _____